



# Grid-Scale Energy Storage with Increased PV And EVs


Paul Brooker

FSEC Advisory Board Meeting

October 21, 2016

#### **Effects of PV on the Grid**

Mismatched supply and demand lead to "the duck curve"








#### **Modeled PV and Baseload Conflict**

- Impacts on utilities will occur before 45% PV
  - NREL predicts 20% PV is sufficient to require energy storage









#### **Modeled PV and Baseload Conflict**

- Impacts on utilities will occur before 45% PV
  - NREL predicts 20% PV is sufficient to require energy storage



But we don't have to wait for PV for storage to become relevant








#### Impact of EVs on the Grid: Residential


- Grid capacity can accommodate Evs for several decades
  - May have local transformer loads exceeded in residential neighborhoods
- Residential TOU rates causes a shift in charge start time
  - Introduces new peaks after midnight









# **Electric Charger Usage**












# Impact of EVs on the Grid: Commercial

- Building demand charges could be increased
  - High number of AC L2 chargers could increase building power levels

Momentary DC fast charge peak could increase costs by > \$300







# Impact of EVs on the Grid: Commercial

- Building demand charges could be increased
  - High number of AC L2 chargers could increase building power levels

Momentary DC fast charge peak could increase costs by > \$300






# **Effect of DC Fast Charging on EBs**

- Tallahassee electric bus route uses in-route fast charging
- Without demand charges = \$0.06/kWh
- With demand charges = \$0.28/kWh

	Electric Bus	Diesel Bus
Efficiency (kWh/mile)	2.5	9.7
Cost per Mile (\$)	0.7	0.9








# **Current Electric System**




Incorporating renewable energy is challenging



**Grid** 



Reserves kept operating for grid stability



Must be stable at 60Hz

Types of power plants:

- Base load
- Load following
- Peaker

Types of grid services:

- Frequency/voltage regulation
  - 0-10s response = low energy
  - 10s-1min response = med energy
  - 1-10min response = high energy
- Spinning reserves
  - Daily load following



# **Electricity Demand Forecasting**

- Daily and seasonal variation requires dayahead forecasting
  - Establish contracts to purchase/sell electricity for the next day
- Actual vs. forecast differences are met through

reserves







Chart from <a href="http://www.eia.gov/todayinenergy/detail.php?id=7070#tabs\_PJM-1">http://www.eia.gov/todayinenergy/detail.php?id=7070#tabs\_PJM-1</a>. Accessed Oct 2016

# Dispatchable vs. Base Generation


- "Dispatchable" = vary power plant output
  - Natural gas power plants
- "Baseload" = constant power output (minor variation acceptable)
  - Nuclear, coal geothermal






# **Power Plant Response Times**

- More rapid response has greater value to grid
  - Steam generators are slow
  - Batteries are nearly instantaneous











# **LCOE** for Generation Technologies







**ENERGY STORAGE** 

Search Greentech Media

#### NextEra on Storage: 'Post 2020, There May Never Be Another Peaker Built in the US'



Energy storage just got a big vote of confidence from one of the world's largest utilities.

GTM RESEARCH 7

GTM EVENTS ↗


by Eric Wesoff September 30, 2015

GTM SQUARED 7

Energy storage at utility scale just got a \$100M vote of confidence from one of the world's largest utilities.


NextEra Energy wants to be "the largest, most profitable clean energy provider in the


















- Lead acid
  - Oldest, most well-known
  - Highly developed recycling chain
  - Lowest cost/kWh
  - Relatively low energy storage capacity
  - < 3 year lifetime</p>



http://www.pospic.com/?image=http://www.wedocable.com/photo/lead-acid-battery-cell-diagram-48902.jpeg&title=Lead%20Acid%20Battery%20Cell%20Diagram&tag=Dry%20Cell%20Battery%20Diagram%20Simple

- Lithium ion
  - Widely accepted in the technology field
  - Employed by EVs more than any other battery
  - Cost/kWh has decreased by 70% in last 8 years
  - < 5 year lifetime</p>






C. Cooper. "Vehicle Technologies Office Overview". Annual Merit Review and Peer Evaluation Meeting, June 6 2016.



- Flow battery
  - NASA technology from the '70s
  - Energy stored in tanks





- All Vanadium
  - Anode:  $V^{2+}/V^{3+}df$
  - Cathode: VO<sup>2+</sup>/VO<sub>2</sub><sup>+</sup>
- High tolerance to deep discharge
- No dendrite formation
- High capital cost (\$>500/ kWh)
- Commercially available (Gildemeister CellCube)
- 🎐 > 15 year lifetime

- Zn-Br
  - Anode: Zn/Zn<sup>2+</sup>
  - Cathode: Br<sup>-</sup>/Br<sub>2</sub>
- Possible dendrite formation
- Oil phase required for bromine stability
- High capital cost
- Commercially available (ZBB, RedFlow)
- > 10 year lifetime



#### **Energy Storage Use Cases**

	Storage Tech	Energy req'd (MWh)	Lifetime (yrs)	100% DOD cyc/ day
Transmission	LA, Li, Flow	800	20	1
Peaker	LA, Li, Flow	100	20	1
Frequency	Li	5	20	4.8
Distribution	LA, Li, Flow	16	20	1
PV Integration	LA, Li, Flow	4	20	1.25
Microgrid	LA, Li, Flow	2	20	2
Island Grid	LA, Li, Flow	6	20	1
Commercial/Industrial	LA, Li, Flow	4	10	1
Commercial appliance	LA, Li, Flow	0.2	10	1
Residential	LA, Li, Flow	0.01	10	1




**Grid operators** 

Buildings



#### **LCOS for Grid-Scale**



Here and throughout this presentation, unless otherwise indicated, analysis assumes 20% debt at 8% interest rate and 80% equity at 12% cost for all technologies and use cases. Assumes seven year MACRS depreciation unless otherwise noted. Analysis does not reflect impact of evolving regulations/rules promulgated pursuant to the EPA's Clean Power Plan.


9 LAZARD

Copyright 2015 Lazard.

No part of this material may be copied, photocopied or duplicated in any form by any means or redistributed without the prior consent of Lazard.

Indicates illustrative conventional alternative to energy storage. Not intended to reflect the sole conventional alternative (or source of value from replacing such alternatives). The lowest cost conventional alternative for a particular use case may not be the lowest cost conventional alternative for another use case.

# **LCOS** for Building Operator



Source: Lazard estimates.

Copyright 2015 Lazard.

Indicates illustrative conventional alternative to energy storage. Not intended to reflect the sole conventional alternative (or source of value from replacing such alternatives). The lowest cost conventional alternative for a particular use case may not be the lowest cost conventional alternative for another use case.


#### **Cost Outlook**








#### **Electric Vehicles**








#### **Electric Vehicles**






OR?



#### Estimated U.S. Energy Consumption in 2015: 97.5 Quads







Source: LLNL March, 2016. Data is based on DOS/EIA MER (2015). If this information or a reproduction of it is used, credit must be given to the Lawrence Livermore National Laboratory and the Department of Energy, under whose auspices the work was performed. Distributed electricity represents only retail electricity sales and does not include self-generation. EIA reports consumption of renewable resources (i.e., hydro, wind, geothermal and solar) for electricity in BTU-equivalent values by assuming a typical fossil fuel plant heat rate. The efficiency of electricity production is calculated as the total retail electricity delivered divided by the primary energy input into electricity generation. End use efficiency is estimated as 55% for the residential sector, 65% for the transportation sector. Totals may not equal sum of components due to independent Rounding. LINI-MI-410552














commercial sector, 80% for the industrial sector, and 21% for the transportation sector. Totals may not equal sum of components due to independent Rounding. LLNL-MI-41052

# **Potential Vision of Future Energy**

#### Future H<sub>2</sub> at Scale Energy System









30

H2 at Scale HTAC 040616


#### **V2G Locations**







Ancillary Service	Minimum Power	Required Interval	Energy/vehicle	Ideal Locations for V2G
Frequency regulation	1 MW (primary) 2-3 MW (secondary) 10 MW (tertiary)	0 sec – 10 min 30 sec – 30 min 30 min – 6 hr	Up to 1 kWh 0.05 – 3 kWh 3 – 40 kWh	Home, Work, Shopping, Social Home, Work, Shopping, Social Home, Work
Peak Shaving	50-500 kW	2 – 10 hr	6 – 60 kWh	Home, Work
Load shifting	100 kW-2 MW	20 min – 1.5 hr	2 – 10 kWh	Home, Work
Back-up Power	5kW (residential) 500kW (commercial)	5 hr – 5 days	25 – 600 kWh 33 – 800 kWh	

#### **V2G Locations**







gy/vehicle	Ideal Locations for V2G
o 1 kWh – 3 kWh 0 kWh	Home, Work, Shopping, Social Home, Work, Shopping, Social Home, Work
0 kWh	Home, Work
0 kWh	Home, Work
600 kWh 800 kWh	