

**Appendix H**

**Sample DOE 2.1D Input and Output for Analysis**

```

****   ***   *****   ***   *   ****
* *   * *   *   *   *   *   *   *   *
* *   * *   *   *   *   *   *   *   *
* *   * *   *   *   *   *   *   *   *
****   ***   *****   ***** *   ***   ****

```

BUILDING ENERGY ANALYSIS PROGRAM

DEVELOPED BY

LAWRENCE BERKELEY LABORATORY/UNIVERSITY OF CALIFORNIA

WITH MAJOR SUPPORT FROM

UNITED STATES DEPARTMENT OF ENERGY  
 ASSISTANT SECRETARY FOR CONSERVATION AND RENEWABLE ENERGY  
 OFFICE OF BUILDINGS AND COMMUNITY SYSTEMS  
 BUILDING SYSTEMS DIVISION

```

***** LEGAL NOTICE *****
*
* THIS PROGRAM WAS PREPARED AS AN ACCOUNT OF WORK SPONSORED BY THE
* UNITED STATES GOVERNMENT. NEITHER THE UNITED STATES NOR THE DEPART-
* MENT OF ENERGY, NOR ANY OF THEIR EMPLOYEES, NOR ANY OF THEIR CON-
* TRACTORS, SUBCONTRACTORS, OR THEIR EMPLOYEES, MAKES ANY WARRANTY,
* EXPRESS OR IMPLIED, OR ASSUMES ANY LEGAL LIABILITY OR RESPONSIBILITY
* FOR THE ACCURACY, COMPLETENESS OR USEFULNESS OF ANY INFORMATION, APPA-
* RATUS, PRODUCT OR PROCESS DISCLOSED, OR REPRESENTS THAT ITS USE WOULD
* NOT INFRINGE PRIVATELY OWNED RIGHTS.
*
*****

```

INPUT LOADS ..

TITLE LINE-1 \*Single Family Residence Base Case \*  
 LINE-2 \*---New 1500 Square Ft Prototype---\*  
 LINE-3 \* Frame Construction for Miami \*  
 LINE-4 \* REFERENCE CASE \*  
 LINE-5 \* D. Parker/ Nov. 18, 1992 \* ..

DIAGNOSTIC ERRORS, NO-ECHO ..  
 RUN-PERIOD JAN 1 1989 THRU DEC 31 1989 ..  
 BUILDING-LOCATION LAT=25.5 LON=80.2 T-Z=5  
 AZIMUTH=0 DAYLIGHT-SAVINGS= YES ..  
 LOADS-REPORT SUMMARY=(LS-B) ..

\$---SCHEDULE---\$

SCH-1 =DAY-SCHEDULE (1) (.32) (2) (.30) (3,4) (.29) (5) (.31)  
 (6) (.46) (7) (.39) (8) (.44) (9) (.46) (10) (.56)  
 (11) (.63) (12) (.59) (13) (.55) (14) (.52)  
 (15) (.57) (16) (.48) (17) (.56) (18) (.77)  
 (19) (.82) (20) (.84) (21) (.99) (22) (1.00)  
 (23) (.69) (24) (.47) ..  
 INT-LDS-1 =SCHEDULE THRU DEC 31 (ALL) SCH-1 ..

\$---MATERIALS---\$

STUD-1 =MAT TH=.2917 COND=.0667 DENS=32 S-H=.33 \$2 X 4 STUDS ..  
 DRYWALL-1 =MAT TH=.0417 COND=.0925 DENS=50 S-H=.26 \$1/2 IN DRYWALLS ..  
 WALL-INS-1 =MAT TH=.2618 COND=.0238 DENS=6 S-H=.2 \$R-11 INSULATIONS ..  
 WALL-INS-2 =MAT TH=.0833 COND=.0238 DENS=6 S-H=.2 \$R-3 INSULATIONS ..  
 SHEATH-1 =MAT TH=.0417 COND=.0342 DENS=22 S-H=.31 \$1/2 IN SHEATHINGS ..  
 AL-SIDE-1 =MAT TH=.0104 COND=.0171 DENS=170 S-H=.29 \$ALUM SIDINGS ..  
 BLOCK-1 =MAT TH=.6667 COND=.6060 DENS=69 S-H=.2 \$8" CON. BLOCKS ..  
 STUCCO-1 =MAT TH=.0833 COND=.4167 DENS=166 S-H=.2 \$STUCCO SIDINGS ..  
 AS-SHG-1 =MAT TH=.0208 COND=.0473 DENS=70 S-H=.30 \$ASPHALT SHINGLES ..  
 PLYW-1 =MAT TH=.0417 COND=.0667 DENS=34 S-H=.29 \$1/2 IN PLYWOODS ..  
 CEIL-INS-1 =MAT TH=.4522 COND=.0238 DENS=6 S-H=.2 \$R-19 INSULATIONS ..  
 AT-AIR-1 =MAT RES=3.1 \$ATTIC AIR SPACES ..  
 EXP-POLY-1 =MAT TH=.0833 COND=.0167 DENS=2.2 S-H=.29 \$1 IN POLYSTYRENES ..  
 CONCRETE-1 =MAT TH=.3333 COND=.7576 DENS=140 S-H=.2 \$4 IN CONCRETES ..  
 CARP/PAD-1 =MAT RES=2.08 \$SCARPET AND PADS ..

\$---GLAZINGS---\$

GT-WIN-1 =GLASS-TYPE PANES=1 S-C=.6 GLASS-CONDUCTANCE = 1.1 ..  
 GT-WIN-2 = GLASS-TYPE PANES=1 S-C=.6 GLASS-CONDUCTANCE = 1.1 ..

\$---CONSTRUCTIONS---\$

LAY-1 =LAYERS MAT=(AL-SIDE-1, SHEATH-1, WALL-INS-1, DRYWALL-1) ..  
 INS-WL-1 =CONS LAYERS=LAY-1 ROUGHNESS=6 ABS = 0.6 ..  
 LAY-2 =LAYERS MAT=(AL-SIDE-1, SHEATH-1, STUD-1, DRYWALL-1) ..  
 STUD-WL-1 =CONS LAYERS=LAY-2 ROUGHNESS=6 ABS = 0.6 ..  
 LAY-3 =LAYERS MAT=(AS-SHG-1, PLYW-1, AT-AIR-1, CEIL-INS-1,  
 DRYWALL-1) I-F-R=.61 ..  
 INS-RF-1 =CONS LAYERS=LAY-3 ABS=.8 ..  
 LAY-4 =LAYERS MAT=(AS-SHG-1, PLYW-1, STUD-1, AT-AIR-1, STUD-1,  
 DRYWALL-1) I-F-R=.92 ..  
 STUD-RF-1 =CONS LAYERS=LAY-4 ABS=.8 ..  
 LAY-5 =LAYERS MAT=(EXP-POLY-1, CONCRETE-1, CARP/PAD-1)  
 I-F-R=.92 ..  
 SLAB-1 =CONS LAYERS=LAY-5 ..  
 DR-1 =CONS U=.6 ABS=.6 ROUGHNESS=4 ..

\$---BUILDING SHADE---\$

BUILDING-SHADE X=0 Y=0 Z=8 H=2 W=50 \$FRONT OVERHANGS  
 AZ=180 TILT=180 ..  
 BUILDING-SHADE X=0 Y=30 Z=8 H=2 W=50 \$REAR OVERHANGS  
 AZ=180 TILT=0 ..

\$----SPACE DESCRIPTIONS----\$

COND-1 =SPACE-CONDITIONS SOURCE-SCHEDULE=INT-LDS-1  
 SOURCE-TYPE=PROCESS SOURCE-BTU/HR=4304  
 INF-METHOD=AIR-CHANGE FLOOR-WEIGHT = 0  
 AIR-CHANGES/HR = 0.40 ..

HOUSE-1 =SPACE A=1500 V=12000 S-C=COND-1 ..

FRONT-WL-1=E-W H=8 W=43.75 AZ=180 CONS=INS-WL-1 ..  
 WIN-1 =WI H=4.5 W=15.56 G-T=GT-WIN-1 X=18 Y=0 ..  
 DOOR-1 =DOOR H=6.67 W=3 CONS=DR-1 X=24.5 ..

FRONT-WL-2=E-W H=8 W=6.25 AZ=180 CONS=STUD-RF-1 ..

RIGHT-WL-1=E-W H=8 W=26.25 AZ=90 X=50 Y=0 CONS=INS-WL-1 ..  
 WIN-2 =WI H=4.5 W=9.33 G-T=GT-WIN-2 X=50 Y=14 ..

RIGHT-WL-2=E-W H=8 W=3.75 AZ=90 X=50 Y=0 CONS=STUD-WL-1 ..

REAR-WL-1=E-W LIKE FRONT-WL-1 W=43.75 X=50 Y=30 AZ=0 ..  
 WIN-3 =WI H=4.5 W=15.56 X=21 Y=0 G-T=GT-WIN-1  
 RIGHT-FIN-A = 10 RIGHT-FIN-H= 8 RIGHT-FIN-D = 24 ..

REAR-WL-2=E-W LIKE FRONT-WL-2 W=6.25 X=50 Y=30 AZ=0 ..

LEFT-WL-1=E-W LIKE RIGHT-WL-1 X=0 Y=30 AZ=270 ..  
 WIN-4 =WI H=4.5 W=9.33 G-T=GT-WIN-2 X=0 Y=14 ..

LEFT-WL-2=E-W LIKE RIGHT-WL-2 X=0 Y=30 AZ=270 ..

FRONT-RF-1=ROOF H=15 W=45 Z=8 AZ=180 TILT=22.62  
 CONS=INS-RF-1 ..

FRONT-RF-2=ROOF H=15 W=5 Z=8 AZ=180 TILT=22.62  
 CONS=STUD-RF-1 ..

REAR-RF-1=ROOF LIKE FRONT-RF-1 X=50 Y=30 AZ=0 ..

REAR-RF-2=ROOF LIKE FRONT-RF-2 X=50 Y=30 AZ=0 ..

U-F CONS=SLAB-1 A=160 \$PERIMETER AREAS ..

END ..  
 COMPUTE LOADS ..  
 INPUT SYSTEMS ..  
 SYSTEMS-REPORT SUMMARY=(SS-J, SS-H) ..

\$---SCHEDULES---

HEAT-1 =SCHEDULE THRU MAR 31 (WD) (1,7) (68) (8,17) (69)  
 (18,23) (70) (24) (68)  
 (WEH) (1,8) (68) (9,24) (70)  
 THRU NOV 30 (ALL) (1,24) (55)  
 THRU DEC 31 (WD) (1,7) (68) (8,17) (69)  
 (18,23) (70) (24) (68)  
 (WEH) (1,8) (68) (9,24) (70) ..

COOL-1 =SCHEDULE THRU JAN 31 (ALL) (1,24) (150)  
 THRU NOV 30 (WD) (1,7) (78) (8,17) (80)  
 (18,24) (78)  
 (WEH) (1,24) (78)  
 THRU DEC 31 (ALL) (1,24) (150) ..  
 THRU DEC 31 (ALL) (1,24) (1) ..  
 THRU DEC 31 (ALL) (1,24) (68) ..

VENT-1 =SCHEDULE  
 VENTING =SCHEDULE THRU DEC 31 (ALL) (1,24) (68) ..

HOUSE-1 =ZONE DESIGN-HEAT-T=70 DESIGN-COOL-T=78  
 ZONE-TYPE=CONDITIONED  
 ASSIGNED-CFM=1200  
 THERMOSTAT-TYPE=TWO-POSITION  
 HEAT-TEMP-SCH=HEAT-1  
 COOL-TEMP-SCH=COOL-1 ..

\$--AIR CONDITIONER AND HEATING SYSTEM PARAMETERS--\$

SYS-1 =SYSTEM SYSTEM-TYPE=RESYS ZONE-NAMES=(HOUSE-1)  
 MAX-SUPPLY-T=140 MIN-SUPPLY-T=50  
 COOLING-CAPACITY=36000  
 COOL-SH-CAP=22500 COOLING-EIR=.3333  
 HEATING-CAPACITY=-40000  
 HEAT-SOURCE= ELECTRIC FURNACE-AUX=100  
 NATURAL-VENT-AC=10 NATURAL-VENT-SCH=VENT-1  
 VENT-TEMP-SCH= VENTING ..

END ..  
 COMPUTE SYSTEMS ..

LDL PROCESSOR INPUT DATA

12/11/1992 18:03:09 LDL RUN 1

\* 2 \* TITLE LINE-1 \*Single Family Residence Base Case \*  
\* 3 \* LINE-2 \*---New 1500 Square Ft Prototype---\*  
\* 4 \* LINE-3 \* Frame Construction for Miami \*  
\* 5 \* LINE-4 \* REFERENCE CASE \*  
\* 6 \* LINE-5 \* D. Parker/ Nov. 18, 1992 \* ..  
\* 7 \*  
\* 8 \* DIAGNOSTIC ERRORS, NO-ECHO ..  
\* 118 \* COMPUTE LOADS ..  
\* 119 \* INPUT SYSTEMS ..

SDL PROCESSOR INPUT DATA

12/11/1992 18:03:09 SDL RUN 1

\* 160 \* COMPUTE SYSTEMS ..  
\* 161 \* STOP ..

SPACE HOUSE-1

MULTIPLIER 1.0 FLOOR MULTIPLIER 1.0  
 FLOOR AREA 1500 SQFT 139 M2  
 VOLUME 12000 CUFT 340 M3

| TIME                 | COOLING LOAD    |        |               |        | HEATING LOAD    |        |               |  |
|----------------------|-----------------|--------|---------------|--------|-----------------|--------|---------------|--|
|                      | APR 2 3PM       |        |               |        | DEC 16 7AM      |        |               |  |
| DRY-BULB TEMP        | 89F             | 32C    |               |        | 35F             | 2C     |               |  |
| WET-BULB TEMP        | 73F             | 23C    |               |        | 32F             | 0C     |               |  |
|                      | SENSIBLE        |        | LATENT        |        | SENSIBLE        |        |               |  |
|                      | (KBTU/H)        | ( KW ) | (KBTU/H)      | ( KW ) | (KBTU/H)        | ( KW ) |               |  |
| WALLS                | 1.206           | 0.353  | 0.000         | 0.000  | -2.340          | -0.685 |               |  |
| ROOFS                | 1.432           | 0.419  | 0.000         | 0.000  | -1.909          | -0.559 |               |  |
| GLASS CONDUCTION     | 3.169           | 0.928  | 0.000         | 0.000  | -6.612          | -1.936 |               |  |
| GLASS SOLAR          | 4.614           | 1.351  | 0.000         | 0.000  | 0.365           | 0.107  |               |  |
| DOOR                 | 0.163           | 0.048  | 0.000         | 0.000  | -0.358          | -0.105 |               |  |
| INTERNAL SURFACES    | 0.000           | 0.000  | 0.000         | 0.000  | 0.000           | 0.000  |               |  |
| UNDERGROUND SURFACES | 0.094           | 0.028  | 0.000         | 0.000  | 0.104           | 0.030  |               |  |
| OCCUPANTS TO SPACE   | 0.000           | 0.000  | 0.000         | 0.000  | 0.000           | 0.000  |               |  |
| LIGHT TO SPACE       | 0.000           | 0.000  | 0.000         | 0.000  | 0.000           | 0.000  |               |  |
| EQUIPMENT TO SPACE   | 0.000           | 0.000  | 0.000         | 0.000  | 0.000           | 0.000  |               |  |
| PROCESS TO SPACE     | 2.089           | 0.612  | 0.000         | 0.000  | 1.484           | 0.435  |               |  |
| INFILTRATION         | 4.706           | 1.378  | 5.236         | 1.533  | -3.514          | -1.029 |               |  |
| TOTAL                | 17.473          | 5.117  | 5.236         | 1.533  | -12.779         | -3.743 |               |  |
| TOTAL LOAD           | 22.709 KBTU/H   |        | 6.651 KW      |        | -12.779 KBTU/H  |        | -3.743 KW     |  |
| TOTAL LOAD / AREA    | 15.14BTU/H.SQFT |        | 47.726 W / M2 |        | 8.519BTU/H.SQFT |        | 26.857 W / M2 |  |

\*\*\*\*\*  
 \* NOTE 1)THE ABOVE LOADS EXCLUDE OUTSIDE VENTILATION AIR \*  
 \* ---- LOADS \*  
 \* 2)TIMES GIVEN IN STANDARD TIME FOR THE LOCATION \*  
 \* IN CONSIDERATION \*  
 \* \*\*\*\*\*

| SYSTEM NAME | ALTITUDE MULTIPLIER |              |                  |                    |                  |                            | COOLING            |                            | HEATING                    |                            | COOLING               |                       | HEATING |  |
|-------------|---------------------|--------------|------------------|--------------------|------------------|----------------------------|--------------------|----------------------------|----------------------------|----------------------------|-----------------------|-----------------------|---------|--|
|             |                     |              | RETURN FAN (CFM) | ELEC (KW)          | DELTA-T (F)      | OUTSIDE AIR RATIO          | CAPACITY (KBTU/HR) | SENSIBLE (SHR)             | CAPACITY (KBTU/HR)         | EIR (BTU/BTU)              | EIR (BTU/BTU)         |                       |         |  |
| SYS-1       | 1.000               |              |                  |                    |                  |                            |                    |                            |                            |                            |                       |                       |         |  |
|             | SUPPLY FAN (CFM)    | ELEC (KW)    | DELTA-T (F)      | RETURN FAN (CFM)   | ELEC (KW)        | DELTA-T (F)                | OUTSIDE AIR RATIO  | COOLING CAPACITY (KBTU/HR) | SENSIBLE (SHR)             | HEATING CAPACITY (KBTU/HR) | COOLING EIR (BTU/BTU) | HEATING EIR (BTU/BTU) |         |  |
|             | 1200.               | 0.154        | 0.4              | 0.                 | 0.000            | 0.0                        | 0.000              | 36.000                     | 0.625                      | -40.000                    | 0.33                  | 0.37                  |         |  |
| ZONE NAME   | SUPPLY FLOW         | EXHAUST FLOW | FAN (KW)         | MINIMUM FLOW RATIO | OUTSIDE AIR FLOW | COOLING CAPACITY (KBTU/HR) | SENSIBLE (SHR)     | EXTRACTION RATE (KBTU/HR)  | HEATING CAPACITY (KBTU/HR) | ADDITION RATE (KBTU/HR)    | MULTIPLIER            |                       |         |  |
| HOUSE-1     | 1200.               | 0.           | 0.000            | 1.000              | 0.               | 0.00                       | 0.00               | 30.30                      | 0.00                       | -40.47                     | 1.0                   |                       |         |  |

| HOUR | --- COOLING ---            |                     |               |               | --- HEATING ---            |               |               | DAY COOLING PEAK           |                     |               |               |
|------|----------------------------|---------------------|---------------|---------------|----------------------------|---------------|---------------|----------------------------|---------------------|---------------|---------------|
|      | HOURLY COOLING LOAD (KBTU) | SENSIBLE HEAT RATIO | DRY-BULB TEMP | WET-BULB TEMP | HOURLY HEATING LOAD (KBTU) | DRY-BULB TEMP | WET-BULB TEMP | HOURLY COOLING LOAD (KBTU) | SENSIBLE HEAT RATIO | DRY-BULB TEMP | WET-BULB TEMP |
|      |                            |                     |               |               |                            |               |               |                            |                     |               |               |
|      |                            |                     | MAY 3         |               |                            |               | DEC 16        |                            |                     |               | AUG 4         |
| 1    | 4.157                      | 0.596               | 80.F          | 77.F          | -8.016                     | 41.F          | 37.F          | 5.155                      | 0.632               | 82.F          | 75.F          |
| 2    | 4.096                      | 0.560               | 80.F          | 77.F          | -8.759                     | 40.F          | 37.F          | 4.576                      | 0.643               | 82.F          | 75.F          |
| 3    | 3.171                      | 0.541               | 78.F          | 77.F          | -9.082                     | 38.F          | 36.F          | 4.265                      | 0.645               | 82.F          | 75.F          |
| 4    | 0.000                      | 0.000               | 77.F          | 76.F          | -9.353                     | 37.F          | 35.F          | 4.324                      | 0.619               | 82.F          | 76.F          |
| 5    | 0.000                      | 0.000               | 77.F          | 76.F          | -10.201                    | 36.F          | 34.F          | 4.818                      | 0.617               | 82.F          | 76.F          |
| 6    | 0.000                      | 0.000               | 76.F          | 75.F          | -10.837                    | 36.F          | 33.F          | 4.280                      | 0.630               | 82.F          | 77.F          |
| 7    | 0.000                      | 0.000               | 77.F          | 76.F          | -11.768                    | 35.F          | 32.F          | 1.805                      | 0.634               | 82.F          | 76.F          |
| 8    | 3.625                      | 0.621               | 80.F          | 77.F          | -9.163                     | 39.F          | 34.F          | 6.380                      | 0.652               | 85.F          | 76.F          |
| 9    | 8.557                      | 0.639               | 83.F          | 78.F          | -8.210                     | 42.F          | 36.F          | 8.102                      | 0.651               | 83.F          | 76.F          |
| 10   | 10.117                     | 0.725               | 84.F          | 77.F          | -4.259                     | 46.F          | 38.F          | 10.537                     | 0.722               | 87.F          | 77.F          |
| 11   | 12.312                     | 0.708               | 86.F          | 77.F          | -1.520                     | 50.F          | 40.F          | 12.816                     | 0.723               | 88.F          | 77.F          |
| 12   | 12.690                     | 0.753               | 89.F          | 77.F          | 0.000                      | 53.F          | 41.F          | 14.021                     | 0.695               | 88.F          | 78.F          |
| 13   | 13.944                     | 0.739               | 90.F          | 77.F          | 0.000                      | 57.F          | 42.F          | 13.977                     | 0.721               | 88.F          | 76.F          |
| 14   | 14.340                     | 0.744               | 88.F          | 76.F          | 0.000                      | 58.F          | 43.F          | 14.685                     | 0.733               | 89.F          | 77.F          |
| 15   | 14.755                     | 0.759               | 88.F          | 76.F          | 0.000                      | 59.F          | 44.F          | 15.609                     | 0.733               | 89.F          | 77.F          |
| 16   | 16.172                     | 0.753               | 88.F          | 76.F          | 0.000                      | 60.F          | 45.F          | 13.726                     | 0.758               | 85.F          | 76.F          |
| 17   | 20.184                     | 0.748               | 86.F          | 77.F          | 0.000                      | 57.F          | 43.F          | 19.773                     | 0.754               | 87.F          | 77.F          |
| 18   | 16.368                     | 0.747               | 85.F          | 76.F          | -0.741                     | 53.F          | 42.F          | 16.421                     | 0.709               | 85.F          | 78.F          |
| 19   | 11.923                     | 0.748               | 82.F          | 76.F          | -2.054                     | 50.F          | 40.F          | 14.502                     | 0.665               | 84.F          | 77.F          |
| 20   | 10.448                     | 0.713               | 81.F          | 76.F          | -3.237                     | 49.F          | 41.F          | 12.689                     | 0.656               | 83.F          | 77.F          |
| 21   | 8.817                      | 0.691               | 79.F          | 75.F          | -3.920                     | 48.F          | 42.F          | 11.163                     | 0.647               | 82.F          | 77.F          |
| 22   | 6.924                      | 0.665               | 79.F          | 75.F          | -4.690                     | 47.F          | 43.F          | 9.097                      | 0.637               | 82.F          | 77.F          |
| 23   | 0.000                      | 0.000               | 76.F          | 72.F          | -5.452                     | 47.F          | 42.F          | 6.904                      | 0.564               | 79.F          | 78.F          |
| 24   | 0.000                      | 0.000               | 73.F          | 70.F          | -5.972                     | 47.F          | 42.F          | 4.000                      | 0.700               | 79.F          | 74.F          |
| SUM  |                            |                     |               |               |                            |               |               | 233.624                    |                     |               |               |
| MAX  | 20.184                     |                     |               |               | -11.768                    |               |               |                            |                     |               |               |



| MTH   | -FAN ELEC-       |                       | -FUEL HEAT-           |                                | -FUEL COOL-           |                                | -ELEC HEAT-           |                            | -ELEC COOL-           |                            |
|-------|------------------|-----------------------|-----------------------|--------------------------------|-----------------------|--------------------------------|-----------------------|----------------------------|-----------------------|----------------------------|
|       | FAN ENERGY (KWH) | MAXIMUM FAN LOAD (KW) | GAS OIL ENERGY (MBTU) | MAXIMUM GAS OIL LOAD (KBTU/HR) | GAS OIL ENERGY (MBTU) | MAXIMUM GAS OIL LOAD (KBTU/HR) | ELECTRIC ENERGY (KWH) | MAXIMUM ELECTRIC LOAD (KW) | ELECTRIC ENERGY (KWH) | MAXIMUM ELECTRIC LOAD (KW) |
| JAN   | 2.               | 0.042                 | 0.000                 | 0.000                          | 0.000                 | 0.000                          | 149.                  | 3.208                      | 11.                   | 0.050                      |
| FEB   | 7.               | 0.072                 | 0.000                 | 0.000                          | 0.000                 | 0.000                          | 116.                  | 2.406                      | 124.                  | 1.463                      |
| MAR   | 7.               | 0.077                 | 0.000                 | 0.000                          | 0.000                 | 0.000                          | 8.                    | 0.947                      | 166.                  | 1.502                      |
| APR   | 12.              | 0.087                 | 0.000                 | 0.000                          | 0.000                 | 0.000                          | 0.                    | 0.000                      | 268.                  | 1.747                      |
| MAY   | 17.              | 0.102                 | 0.000                 | 0.000                          | 0.000                 | 0.000                          | 0.                    | 0.000                      | 406.                  | 1.973                      |
| JUN   | 23.              | 0.099                 | 0.000                 | 0.000                          | 0.000                 | 0.000                          | 0.                    | 0.000                      | 547.                  | 1.912                      |
| JUL   | 25.              | 0.101                 | 0.000                 | 0.000                          | 0.000                 | 0.000                          | 0.                    | 0.000                      | 573.                  | 1.908                      |
| AUG   | 28.              | 0.105                 | 0.000                 | 0.000                          | 0.000                 | 0.000                          | 0.                    | 0.000                      | 669.                  | 2.014                      |
| SEP   | 25.              | 0.095                 | 0.000                 | 0.000                          | 0.000                 | 0.000                          | 0.                    | 0.000                      | 599.                  | 1.830                      |
| OCT   | 16.              | 0.099                 | 0.000                 | 0.000                          | 0.000                 | 0.000                          | 0.                    | 0.000                      | 380.                  | 1.834                      |
| NOV   | 9.               | 0.075                 | 0.000                 | 0.000                          | 0.000                 | 0.000                          | 0.                    | 0.000                      | 203.                  | 1.470                      |
| DEC   | 3.               | 0.045                 | 0.000                 | 0.000                          | 0.000                 | 0.000                          | 203.                  | 3.447                      | 13.                   | 0.050                      |
| TOTAL | 175.             |                       | 0.000                 |                                | 0.000                 |                                | 476.                  |                            | 3960.                 |                            |
| MAX   |                  | 0.105                 |                       | 0.000                          |                       | 0.000                          |                       | 3.447                      |                       | 2.014                      |